

Idoneità del tubo multistrato metallo-plastici e dei relativi raccordi in PPSU a trasportare acqua potabile calda e fredda (AS/NZS 4020).

Suitability of multilayer metal-plastic pipes and relative fittings in PPSU plastic for transporting hot and cold drinking water (AS/NZS 4020).



GPO Box 1751  
Adelaide SA 5001

250 Victoria Square  
Adelaide SA 5000

Tel: 1300 653 366  
Fax: 1300 883 186

Internet: www.awqc.com.au  
Email: awqc@sawater.com.au

## FINAL REPORT

REPORT ID 128971V

### REPORT INFORMATION SUBMITTING ORGANISATION

00109049: VIPAC Engineers & Scientists Ltd

### ACCOUNT

130044: VIPAC Engineers & Scientists Ltd – AS/NZS 4020 Testing.

### AWQC REFERENCE

130044-2012-CSR-13 Prod Test: Valsir System.

### PROJECT REFERENCE

PT-2141V

### PRODUCT DESIGNATION

Valsir 16 x 16 90° ELBOW and PE-X /Al/PE-X Multilayer Pipe.

### COMPOSITION OF PRODUCT

PPSU Plastic Elbow Fitting and PE-X/Al/PE-X Pipe.

### PRODUCT MANUFACTURER

Valsir S.p.A., Località Merlaro, Vestone (BS), ITALY.

### USE OF PRODUCT

In-Line/Fittings and Pipe System for Hot and Cold Water Applications.

### SAMPLE SELECTION

As provided by the submitting organisation.

### TESTING REQUESTED

**AS/NZS 4020:2005 TESTING OF PRODUCTS FOR USE IN CONTACT WITH DRINKING WATER**

### PRODUCT TYPE

Composite.

### SAMPLES

SAMPLES WERE PREPARED AND CONTROLLED AS DESCRIBED IN APPENDIX A OF AS/NZS 4020:2005.

### EXTRACTS

Extracts were prepared and controlled as described in Appendix C, D, E, F, G, H.

PROJECT COMPLETION DATE 02/12/2013

### PROJECT COMMENT

The results presented herein demonstrate compliance of Valsir 16 x 16 95° Elbow and PE-X /Al/PE-X Multilayer Pipe to AS/NZS 4020 when tested at the in-the-product exposure (343,348 mm<sup>2</sup>/L) at 95°C ± 2°C.

**PLEASE NOTE THAT THIS REPORT SHALL NOT BE REPRODUCED EXCEPT IN FULL.**

**THE RESULTS STATED IN THIS REPORT RELATE TO THE SAMPLE OF THE PRODUCT SUBMITTED FOR TESTING. ANY CHANGES IN THE MATERIAL FORMULATION, PROCESS OF MANUFACTURE, THE METHOD OF APPLICATION, OR THE SURFACE AREA-TO-VOLUME RATIO IN THE END USE, COULD AFFECT THE SUITABILITY OF THE PRODUCT FOR USE IN CONTACT WITH DRINKING WATER.**



M. GLASSON  
APPROVED SIGNATORY



CERTIFIED QUALITY  
MANAGEMENT SYSTEM  
2008

Page 1 of 11

Idoneità del tubo multistrato metallo-plastici e dei relativi raccordi in PPSU a trasportare acqua potabile calda e fredda (AS/NZS 4020).

Suitability of multilayer metal-plastic pipes and relative fittings in PPSU plastic for transporting hot and cold drinking water (AS/NZS 4020).



GPO Box 751  
Adelaide SA 5001

250 Victoria Square  
Adelaide SA 5000

Tel: 1300 653 366  
Fax: 1300 883 196

Internet: www.awqc.com.au  
Email: awqc@sawater.com.au

## FINAL REPORT

REPORT ID 128971V  
Summary of Results

APPENDIX	RESULTS
C - TASTE OF WATER EXTRACT	Passed when tested at the in-the-product exposure (343,348 mm <sup>2</sup> /L).
D - APPEARANCE OF WATER EXTRACT	Passed when tested at the in-the-product exposure (343,348 mm <sup>2</sup> /L).
E - GROWTH OF AQUATIC MICRO-ORGANISMS	Passed when tested at the in-use exposure.
F - CYTOTOXIC ACTIVITY OF WATER EXTRACT	Passed when tested at the in-the-product exposure (343,348 mm <sup>2</sup> /L).
G - MUTAGENIC ACTIVITY OF WATER EXTRACT	Passed when tested at the in-the-product exposure (343,348 mm <sup>2</sup> /L).
H - EXTRACTION OF METALS	Passed when tested at the in-the-product exposure (343,348 mm <sup>2</sup> /L).

### Test Methods

Test(s)	AWQC Test Method	Reference Method
C	T0320-1	AS/NZS 4020:2005
D	T0029-01 & T0018-01	APHA 2130b
E	T0014-03	APHA 4500 O C
F	TM-001	AS/NZS 4020:2005
G	TM-002	AS/NZS 4020:2005
H	TIC-006	EPA 200.8



Page 2 of 11

Idoneità del tubo multistrato metallo-plastici e dei relativi raccordi in PPSU a trasportare acqua potabile calda e fredda (AS/NZS 4020).

*Suitability of multilayer metal-plastic pipes and relative fittings in PPSU plastic for transporting hot and cold drinking water (AS/NZS 4020).*



GPO Box 1751  
Adelaide SA 5001

250 Victoria Square  
Adelaide SA 5000

Tel: 1300 653 366  
Fax: 1300 693 196

Internet: [www.awqc.com.au](http://www.awqc.com.au)  
Email: [awcc@sawater.com.au](mailto:awcc@sawater.com.au)

## FINAL REPORT

REPORT ID 128971V

### SUMMARY COMMENT

The sample was initially tested as a complete system of brass elbow, PPSU elbow and pipe assembly with an in-the-product exposure of (343,348 mm<sup>2</sup>/L).

The sample exceeded the maximum allowable concentration for Lead (Pb) under Appendix H – Extraction of Metals thus the brass elbow was omitted from the system and the remaining PPSU elbow and Pipe Assembly passed when tested at the in-the-product exposure (343,348 mm<sup>2</sup>/L) at 95°C ± 2°C.

WALSIIR®



Page 3 of 11

Idoneità del tubo multistrato metallo-plastici e dei relativi raccordi in PPSU a trasportare acqua potabile calda e fredda (AS/NZS 4020).

Suitability of multilayer metal-plastic pipes and relative fittings in PPSU plastic for transporting hot and cold drinking water (AS/NZS 4020).



GPO Box 1751  
Adelaide SA 5001

250 Victoria Square  
Adelaide SA 5000

Tel: 1300 653 366  
Fax: 1300 883 196

Internet: [www.awqc.com.au](http://www.awqc.com.au)  
Email: [awqc@sawater.com.au](mailto:awqc@sawater.com.au)

## FINAL REPORT

REPORT ID 128971V

### CLAUSE 6.2 Taste of Water Extract

**SAMPLE DESCRIPTION** The sample consisted of three lengths of pipe and two fittings in an assembly with an internal diameter of 11.65 mm providing an exposure of approximately 343,348 mm<sup>2</sup> per Litre.

Extracts were prepared using 1000 mL volumes of 50 mg/L hardness water.

**EXTRACTION TEMPERATURE** 95°C ± 2°C

**TEST METHOD** TASTE OF WATER EXTRACT (APPENDIX C)

**SCALING FACTOR** Not applicable.

**RESULTS** No tastes were detected in the controls or in the test extracts prepared at the in-the-product exposure with chlorinated and chlorine-free water.

**EVALUATION** The product passed the requirements of clause 6.2 when tested at the in-the-exposure (343,348 mm<sup>2</sup>/L).

**NUMBER OF SAMPLES** Two samples tested.

**TEST COMMENT** Not applicable.



**APPROVED SIGNATORY**



CERTIFIED QUALITY  
MANAGEMENT SYSTEM  
— ISO 9001 —

Page 4 of 11

Idoneità del tubo multistrato metallo-plastici e dei relativi raccordi in PPSU a trasportare acqua potabile calda e fredda (AS/NZS 4020).

Suitability of multilayer metal-plastic pipes and relative fittings in PPSU plastic for transporting hot and cold drinking water (AS/NZS 4020).



GPO Box 1751  
Adelaide SA 5001

250 Victoria Square  
Adelaide SA 5000

Tel: 1300 653 366  
Fax: 1300 883 196

Internet: www.awqc.com.au  
Email: awqc@awwater.com.au

## FINAL REPORT

**REPORT ID** 128971V

### CLAUSE 6.3 Appearance of Water Extract

**SAMPLE DESCRIPTION** The sample consisted of three lengths of pipe and two fittings in an assembly with an internal diameter of 11.65 mm providing an exposure of approximately 343,348 mm<sup>2</sup> per Litre.

Extracts were prepared using 1000 mL volumes of 50 mg/L hardness water.

**EXTRACTION TEMPERATURE** 95°C ± 2°C

**TEST METHOD** APPEARANCE OF WATER EXTRACT (APPENDIX D)

**SCALING FACTOR** Not applied.

#### RESULTS

	<u>Test (-Blank)</u>	<u>Maximum Allowed</u>	<u>Units</u>
Colour	< 1	5	HU
Turbidity	< 0.1	0.5	NTU

**EVALUATION** The product passed the requirements of clause 6.3 when tested at the in-the-exposure (343,348 mm<sup>2</sup>/L).

**NUMBER OF SAMPLES** One sample tested.

**TEST COMMENT** Not applicable.



**APPROVED SIGNATORY**



Page 5 of 11

Idoneità del tubo multistrato metallo-plastici e dei relativi raccordi in PPSU a trasportare acqua potabile calda e fredda (AS/NZS 4020).

Suitability of multilayer metal-plastic pipes and relative fittings in PPSU plastic for transporting hot and cold drinking water (AS/NZS 4020).



GPO Box 1751  
Adelaide SA 5001

250 Victoria Square  
Adelaide SA 5000

Tel: 1300 653 366  
Fax: 1300 883 196

Internet: [www.awqc.com.au](http://www.awqc.com.au)  
Email: [awqc@sawater.com.au](mailto:awqc@sawater.com.au)

## FINAL REPORT

**REPORT ID** 128971V

### CLAUSE 6.4 Growth of Aquatic Micro-organisms

**SAMPLE DESCRIPTION** The non-metallic components were immersed at the in-use exposure. The surface area of each component was in the range 1000 mm<sup>2</sup> per Litre to 15000 mm<sup>2</sup> per Litre.

Extracts were prepared using 1000 mL volumes of test water.

**EXTRACTION TEMPERATURE** 30°C ± 2°C

**TEST METHOD** GROWTH OF AQUATIC MICRO-ORGANISMS (APPENDIX E)

**INOCULUM** The volume of inoculum was 100 mL

**SCALING FACTOR** Not applied.

<b>RESULTS</b>	Mean Dissolved Oxygen	Control	7.5 mg/L
	Mean Dissolved Oxygen Difference	Positive Reference	5.1 mg/L
		Negative Reference	< 0.1 mg/L
		Test	0.3 mg/L

**EVALUATION** The product passed the requirements of Clause 6.4 when tested at the in-use exposure (the surface area of each component was in the range 1000 mm<sup>2</sup> per Litre to 15000 mm<sup>2</sup> per Litre).

**NUMBER OF SAMPLES** One sample tested.

**TEST COMMENT** Not applicable.



**APPROVED SIGNATORY**



CERTIFIED QUALITY  
WATER TREATMENT  
PRODUCTS  
**Page 6 of 11**



GPO Box 1751  
Adelaide SA 5001

250 Victoria Square  
Adelaide SA 5000

Tel: 1300 653 956  
Fax: 1300 883 196

Internet: www.awqc.com.au  
Email: awqc@sawater.com.au

## FINAL REPORT

**REPORT ID** 128971V

### CLAUSE 6.5 Cytotoxic Activity of Water Extract

#### SAMPLE DESCRIPTION

The sample consisted of three lengths of pipe and two fittings in an assembly with an internal diameter of 11.65 mm providing an exposure of approximately 343,348 mm<sup>2</sup> per Litre.

Extracts were prepared using 1000 mL volumes of 50 mg/L hardness water.

**EXTRACTION TEMPERATURE** 95°C ± 2°C

**TEST METHOD** CYTOTOXIC ACTIVITY OF WATER EXTRACT (APPENDIX F)


**SCALING FACTOR** Not Applicable.

**RESULTS** Non-Cytotoxic.

**EVALUATION** The product passed the requirements of clause 6.5 when tested at the in-the-exposure (343,348 mm<sup>2</sup>/L).

**NUMBER OF SAMPLES** One sample tested.

**TEST COMMENT** The test extracts and blank extracts were used to prepare nutrient growth medium and subsequently used to grow a cell line (ATCC Number CCL 81) in the analysis. In addition zinc sulphate (0.4 mmol) was used for the positive control in the analysis.

  
Brecken Kiy  
**APPROVED SIGNATORY**



CERTIFIED QUALITY  
MANAGEMENT SYSTEM

Page 7 of 11



GPO Box 751  
Adelaide SA 5001

250 Victoria Square  
Adelaide SA 5000

Tel: 1300 653 366  
Fax: 1300 883 196

Internet: www.awqc.com.au  
Email: awqc@sawater.com.au

## FINAL REPORT

REPORT ID 128971V

### CLAUSE 6.6 Mutagenic activity of Water Extract

**SAMPLE DESCRIPTION** The sample consisted of three lengths of pipe and two fittings in an assembly with an internal diameter of 11.65 mm providing an exposure of approximately 343,348 mm<sup>2</sup> per Litre.

Extracts were prepared using 1000 mL volumes of 50 mg/L hardness water.

**EXTRACTION TEMPERATURE** 95°C ± 2°C

**TEST METHOD** MUTAGENIC ACTIVITY OF WATER EXTRACT (APPENDIX G)

**SCALING FACTOR** Not Applicable.

## RESULTS

### BACTERIAL STRAIN

### NUMBER OF REVERTANTS per PLATE

	S9	Blank	Sample Extract	Positive Controls	
				NPD (20ug)	2-AF (20ug)
<i>Salmonella typhimurium</i> TA98	-	21, 18, 22	33, 23, 23	2516, 2440, 2269	
Mean ± Standard deviation		20.3 ± 2.1	26.3 ± 5.8	2408.8 ± 126.5	
	+	15, 25, 26	29, 28, 28	-	2312, 2289, 2482
Mean ± Standard deviation		22.0 ± 6.1	28.3 ± 0.6	-	2361.0 ± 105.4
				AZIDE (1.0ug)	2-AF (20ug)
<i>Salmonella typhimurium</i> TA100	-	369, 342, 373	345, 344, 354	1044, 1126, 1093	
Mean ± Standard deviation		361.3 ± 16.9	347.7 ± 5.5	1087.7 ± 41.3	
	+	284, 239, 305	244, 249, 263	-	2398, 2408, 2568
Mean ± Standard deviation		276.0 ± 33.7	252.0 ± 9.8	-	2458.0 ± 95.4
				MITOMYCIN C (2ug)	
<i>Salmonella typhimurium</i> TA102	-	722, 660, 682	669, 620, 677	2420, 2481, 2357	
Mean ± Standard deviation		688.0 ± 31.4	655.3 ± 30.9	2419.3 ± 62.0	
	+	566, 464, 663	532, 576, 674		
Mean ± Standard deviation		564.3 ± 99.5	594.0 ± 72.7		





Idoneità del tubo multistrato metallo-plastici e dei relativi raccordi in PPSU a trasportare acqua potabile calda e fredda (AS/NZS 4020).

Suitability of multilayer metal-plastic pipes and relative fittings in PPSU plastic for transporting hot and cold drinking water (AS/NZS 4020).



GPO Box 1751  
Adelaide SA 5001

250 Victoria Square  
Adelaide SA 5000

Tel: 1300 653 366  
Fax: 1300 883 136

Internet: [www.awqc.com.au](http://www.awqc.com.au)  
Email: [awqc@sawater.com.au](mailto:awqc@sawater.com.au)

## FINAL REPORT

REPORT ID 128971V

### CLAUSE 6.6 Mutagenic activity of Water Extract

COMMENTS S9 was used as a metabolic activator. NPD (4-nitro-o-phenylenediamine), Azide, and Mitomycin C are specific positive controls for strains TA 98, TA 100 and TA102 respectively while 2 - AF (2-aminofluorene) when used in conjunction with S9 is a positive control for both TA98 and TA100.

EVALUATION The product passed the requirements of clause 6.6 when tested at the in-the-exposure (343,348 mm<sup>2</sup>/L).

NUMBER OF SAMPLES One sample tested.

TEST COMMENT Not applicable.

WALSIIR

*M. Olan*

**APPROVED SIGNATORY**



Page 9 of 11

Idoneità del tubo multistrato metallo-plastici e dei relativi raccordi in PPSU a trasportare acqua potabile calda e fredda (AS/NZS 4020).

Suitability of multilayer metal-plastic pipes and relative fittings in PPSU plastic for transporting hot and cold drinking water (AS/NZS 4020).



GPO box 1751  
Adelaide SA 5001

250 Victoria Square  
Adelaide SA 5000

Tel: 1330 653 366  
Fax: 1300 832 195

Internet: [www.awqc.com.au](http://www.awqc.com.au)  
Email: [awqc@sa.water.com.au](mailto:awqc@sa.water.com.au)

## FINAL REPORT

REPORT ID 128971V

### CLAUSE 6.7 Extraction of Metals

**SAMPLE DESCRIPTION** The sample consisted of three lengths of pipe and two fittings in an assembly with an internal diameter of 11.65 mm providing an exposure of approximately 343,348 mm<sup>2</sup> per Litre.

Extracts were prepared using 1000 mL volumes of 50 mg/L hardness water.

**EXTRACTION TEMPERATURE** 95°C ± 2°C

**TEST METHOD** EXTRACTION OF METALS (APPENDIX H)

**SCALING FACTOR** Not Applicable.

### METHODS OF ANALYSIS

All methods used to determine concentrations of metals are based on those described in the 21st edition of *Standard Methods for the Examination of Water and Wastewater* published by the APHA, AWWA and WEF (2005). The methods have been adapted for the instrumentation in use at the Australian Water Quality Centre.

Concentrations of the metals described in Table 2 of the AS/NZS 4020:2005 are determined as follows:

Antimony, Arsenic, Barium, Cadmium, Chromium, Copper, Lead, Mercury, Molybdenum, Nickel, Selenium and Silver by Inductively Coupled Plasma Mass Spectrometry



Idoneità del tubo multistrato metallo-plastici e dei relativi raccordi in PPSU a trasportare acqua potabile calda e fredda (AS/NZS 4020).

Suitability of multilayer metal-plastic pipes and relative fittings in PPSU plastic for transporting hot and cold drinking water (AS/NZS 4020).



GPO Box 1751  
Adelaide SA 5031

250 Victoria Square  
Adelaide SA 5000

Tel: 1300 653 366  
Fax: 1300 893 196

Internet: www.awqc.com.au  
Email: awqc@sawater.com.au

## FINAL REPORT

REPORT ID 128971V

### CLAUSE 6.7 Extraction of Metals

#### RESULTS

##### Final Extract

	Limit of reporting mg/L	Blank mg/L	Test 1 mg/L	Test 2 mg/L	Max. Allowed mg/L
Antimony	0.0005	< 0.0005	< 0.0005	< 0.0005	0.003
Arsenic	0.0003	< 0.0003	< 0.0003	< 0.0003	0.007
Barium	0.0005	< 0.0005	< 0.0005	< 0.0005	0.7
Cadmium	0.0001	< 0.0001	< 0.0001	< 0.0001	0.002
Chromium	0.0001	< 0.0001	< 0.0001	< 0.0001	0.05
Copper	0.0001	< 0.0001	< 0.0001	< 0.0001	2.0
Lead	0.0001	< 0.0001	< 0.0001	< 0.0001	0.01
Mercury	0.00003	< 0.00003	< 0.00003	< 0.00003	0.001
Molybdenum	0.0001	< 0.0001	< 0.0001	< 0.0001	0.05
Nickel	0.0001	< 0.0001	< 0.0001	< 0.0001	0.02
Selenium	0.0001	< 0.0001	< 0.0001	< 0.0001	0.01
Silver	0.00003	< 0.00003	< 0.00003	< 0.00003	0.1

#### EVALUATION

The product passed the requirements of clause 6.7 when tested at the in-the-exposure (343,348 mm<sup>2</sup>/L).


#### NUMBER OF SAMPLES

One sample - two extracts.

#### TEST COMMENT

The sample initially tested consisted of three lengths of pipe and two fittings (one brass and one PPSU) in an assembly with an internal diameter of 11.65 mm providing an exposure of approximately 343,348 mm<sup>2</sup> per Litre. The sample extracts derived from this assembly exceeded the maximum allowable concentration for Lead (Pb).

The test was repeated whereby the brass elbow was omitted from the system and the PPSU elbow and pipe assembly passed at the in-the-exposure (343,348 mm<sup>2</sup>/L).

  
APPROVED SIGNATORY

**END OF REPORT**



Page 11 of 11